# $oldsymbol{i}^3$ C Mini Intelligent Control Station



- 3.5" TFT Colour Touchscreen
- 65,535 Colours, QVGA (320 x 240)
- MicroSD<sup>™</sup> Data storage upto 32GB
- Real Time Clock
- 1 CAN Port, 1 RS-232, 1 RS-485
- 1 Integral Ethernet Port
- USB Port for Programming
- USB Port for Flash Drives upto 2TB
- Addressable function keys
- 1MB RAM (Program), 27MB (Graphical)
- IP65 (NEMA4)
- 10 30 VDC Power Supply
- Online Programming
- Free Configuration Software
- Remote I/O Communication
- Optional Modem (SMS, GSM, GPRS)




# MO Pump and Level Control Tank Level Tan

# **Options & Ordering Codes**

Standard Options	DI	D0	Al	AO
i3CM12Y/10D03-SEHF	12	6 Relay	4	-
i3CM12Y/13C14-SEHF	12	12	2*	2
i3CM12Y/20B05-SEHF	24	16	2	-
i3CM12Y/10B04-SEHF	12	12	2	-
i3CM12Y/10E24-SEHF	12	12	6*	4
i3CM12Y/00000-SEHF	-	-	-	-

<sup>\*</sup> Universal Analogue Inputs



# $oldsymbol{\dot{i}}^3$ C Mini Intelligent Control Station



# **Technical Specifications**

General Specifications			
Required Power (Steady State)	190mA @ 12VDC / 95mA @ 24VDC		
Required Power (Inrush)	2A for <1ms @ 24VDC DC Switched		
Primary Voltage Range	10-30VDC		
Relative Humidity	5 to 95% Non-Condensing		
Clock Accuracy	+/-20ppm Maximum at 25°C (+/-1 Minute per month)		
Operating Air Temperature	-10°C to +60°C		
Storage Temperature	-30°C to +70°C		
Weight	0.34kg (without I/O)		
Approvals	cUL, UL, CE		

Control & Logic Specifications				
Control Language Support	Advanced Ladder Logic Full IEC 61131-3			
Logic Program Size & Logic Scan Rate	1MB Maximum 0.013ms/k			
Online Programming Changes Supported in Advanced Ladde				
	Digital Inputs - 2048			
I/O Cunnort	Digital Outputs - 2048			
I/O Support	Analogue Inputs - 512			
	Analogue Outputs - 512			
General Purpose Registers	50,000 (words) Retentive 16,384 (bits) Retentive 16,384 (bits) Non-retentive			

Display Specifications				
Display Type	3.5" QVGA TFT			
Resolution	320 x 240			
Colour	16-bit (65,536)			
Screen Memory	27MB			
User-Programmable Screens	1023			
Backlight	LED - 50,000 hour life			
Screen Update Rate	User configurable within the scan time (perceived as instantaneous in many cases)			

Connectivity				
Serial Ports	1 RS-232 & 1 RS-485 on first modular jack (MJ1/2)			
USB mini-B	USB 2.0 (480MHz) Programming & Data Access			
USB A	USB 2.0 (480MHz) for USB FLASH Drives (up to 2TB)			
CAN	Remote I/O, Peer-to-Peer Comms, i3 Configurator			
Ethernet 10/100MB (Auto-MDX), Modbus TCP, HTTP, FTP, SMTP, i3 Configurator, Ethernet IP				
Remote I/O	IOS, Smart I/O, iSmart			
Removable Memory	MicroSD™ (support for 32GB max) Application updates, Datalogging, more			


Model	DC In	DC Out	Relays	HS In	HS Out	mA/V In	ma/v rtd/ tc	mA/V Out	High Speed	I Counters
10D03	12		6	4		4			Number of Counters	2
10B04	12	12		4	2	2			Maximum Frequency	500kHz each
20B05	24	16		4	2	2			Accumulator Size	32-bits each
13C14	12	12		4	2		2	2	Modes Su	ıpported
10E24	12	12		4	2		6*	4*	Totalizer	Quadrature
	0 1				0 1		of the total Analogue I/O.		Pulse Measurement	Frequency Measurement


outputs can be used for PWM and Pulse Train Outputs, currently limited to <65kHz. Model 10E14 features a 14/17 bit Analogue I/O.

2 Position Controlled Outputs 1 ON/OFF Setpoint per Output

# **Dimensions & Panel Cutout**

\*Up to six mA/V In, RTD/TC, and mA/V Out






# $oldsymbol{i}^3$ C Mini Intelligent Control Station



# **Ports & Connectors**



### **DC Input / Frame**

Torque rating: 4.5-7 Lb-in (0.50-0.78Nm)

DC- is internally connected to I/O V-, but is isolated from CAN V-

A Class 2 power supply must be used

Primary Power Port Pins				
Pin Signal Signal Description				
1	Ground	Frame Ground		
2	DC-	Input Power Supply Ground		
3	DC+	Input Power Supply Voltage		



### MJ1/2 Independent Serial Ports

MJ1: RS-232 with Full Handshaking MJ2: RS-485 Half-Duplex

PIN	MJ1 F	PINS	MJ2 F	PINS
	Signal	Direction	Signal	Direction
8	TXD	OUT	-	-
7	RXD	IN	-	-
6	0 V	Ground	0 V	Ground
5	+5V@60mA	OUT	+5V@60mA	OUT
4	RTS	OUT	-	-
3	CTS	IN	-	-
2	-	-	RX- / TX-	IN / OUT
1	-	-	RX+/TX+	IN / OUT



### CAN


Locking Spring-Clamp 2-Terminators Per Conductor Mounting screw torque rating: 4.5 Lb-in (0.50Nm)

SHLD and V+ pins are not internally connected to i<sup>3</sup>C Mini

	Primary Power Port Pins						
Pin	Signal Description Direct						
1	V-	CAN Ground - Black	-				
2	CN L	CAN Data Low - Blue	IN / OUT				
3	SHLD	Shield Ground - None -					
4	CN H	CAN Data High - White IN / OUT					
5	V+ (NC)	No Connect - Red	-				

### **DIP Switches**





Switch	Name	Function	Default
1	RS-485 Termination	ON = Terminated	OFF
2	Spare	Always Off	OFF
3	Factory Use	Always Off	OFF

### Built-in I/O

I/O is mapped into i3 Register space, in three separate areas – Digital/Analogue I/O, High-Speed Counter I/O, and High-Speed Output I/O. Digital/Analogue I/O location is fixed starting at 1, but the High-Speed Counter and High-Speed Output references may be mapped to any open register location. For more details on using the High-Speed Counter and High-Speed Outputs, see the i3C Mini User's Manual.

Fixed	Digital/Analog		i	i3C Mini Mode	I	
Address	I/O Function	10D03	10B04	20B05	13C14	10E24
	Digital Inputs	1-12	1-12	1-24	1-12	1-12
%I1	Reserved	13-32	13-31	25-31	13-31	13-31
	ESCP Alarm	n/a	32	32	32	32
%Q1	Digital Outputs	1-6	1-12	1-16	1-12	1-12
76 U I	Reserved	7-24	13-24	17-24	13-24	13-24
%AI1	Analogue Inputs	1-4	1-2	1-2	1-2	1-4:33-38
70AII	Reserved	5-12	3-12	3-12	3-12	n/a
%AQ1	Reserved	n/a	1-8	1-8	1-8	1-12
%AU I	Analogue Outputs	n/a	n/a	n/a	9-10	n/a

Reserved areas maintain backward compatability with other i3 Controller models

Default Address*	High Speed Counter Function	i3C Mini Models
%I1601	Status Bits	1-8
&Q1601	Command Bits	1-32
%AI0401	Accumulator 1&2	1-8
%AQ0401	Preload & Match Values	1-12

\*Starting Address locations for %I, %Q, %AI & %AQ may be re-mapped by user

Default Address*	High Speed Output Function	i3C Mini Models
%I1617	Status Bits	1-8
&Q**	Command Bits	1-32
n/a	n/a	n/a
%AQ0421	PWM or Pulse Train Parameters	1-20

\*Starting Address locations for %I & %AQ may be re-mapped by user

\*\*Q1-Q2 are part of the Fixed I/O Map. In High Speed Output mode they can be used to initiate a Stepper/PTO Move

# $oldsymbol{\dot{i}}^3$ C Mini Intelligent Control Station




# 13C14 I/O Board Specifications

Digital DC Inputs		Digital DC Outputs		
Inputs per Module	12 including 4 configurable HSC inputs	Outputs per Module	12 including 2 configurable PWM outputs	
Commons per Module	1	Commons per Module	6	
Input Voltage Range	10-30 VDC	Output Type	Sourcing / 10 K Pull-Down	
Absolute Max. Voltage	35 VDC Max	Absolute Max. Voltage	28 VDC Max	
Input Impedance	10 kΩ	Output Protection	Short Circuit	
Input Current	Positive Logic Negative Logic	Max. Output Current per Point	0.5A	
Upper Threshold	0.8mA -1.6mA	Max. Total Current	4 A Continuous	
Lower Threshold	0.3mA -2.1mA	Max. Output Supply Voltage	30 VDC	
Max. Upper Threshold	8 VDC	Min. Output Supply Voltage	10 VDC	
Max. Lower Threshold	3 VDC	Max. Voltage Drop at Rated Current	0.25V	
OFF to ON Response	1 ms	Max. Inrush Current	650 mA per channel	
ON to OFF Response	1 ms	Min. Load	None	
	40 III Talafi av/D laa Edaga Elli Ea	OFF to ON Response	1 ms	
HSC Max. Switching Rate	10 kHz Totalizer/Pulse, Edges 5 kHz Frequency/Pulse, Width 2.5 kHz Quadrature	ON to OFF Response	1 ms	
	quency/r alse, with 2.5 km2 dualitation	Output Characteristics	Current Sourcing (Positive Logic)	
	Analogue Inputs	, High Resolution		
Number of Channels	2	Thermocouple	Temperature Range	
Input Ranges (Selectable)	0 - 10 VDC, 0 – 20 mA, 4 – 20 mA, 100mV PT100 RTD, and J, K, N, T, E, R, S, B Thermocouple	B/R/S E T J K/N	2912°F to 32.0°F (1600°C to 0°C) 1652°F to 328°F (900°C to -200°C) 752.0°F to -400°F (400°C to -240°C) 1382.0°F to -346.0°F (750°C to -210°C) 2498.0°F to -400°F (1370°C to -240°C)	
Nominal Resolution	10V, 20mA, 100mV: 14 Bits RTD, Thermocouple: 16 Bits	Thermocouple Common Mode Range	±10V	
Converter Type	Delta Sigma	Max. Thermocouple Error	±0.2% (±0.3% below -100°C)	
Input Impedance (Clamped @ -0.5 VDC to 12 VDC)	Current Mode: 100 Ω, 35mA Max. Continuous Voltage Mode: 500 kΩ, 35mA Max. Continuous	## 4-20 mA ## 0.10%  ## 4-20 mA ## 0.10%  ## 0-20 mA ## 0.10%  ## 0-10 VDC ## 0.10%  ## BTD (PT100) ## 1.0°C  ## 0-100 mV ## 0.05%		
Al Full Scale	10 V, 20 mA, 100 mV: 32,000 counts full scale.  RTD / T/C: 20 counts / °C	Conversion Speed, Both Channels Converted	10V, 20mA, 100mV: 30 Times/Second RTD, Thermocouple: 7.5 Times/Second	
Max. Over-Current	35mA	Conversion Time per Channel	10V, 20mA, 100mV: 16.7mS RTD, Thermocouple: 66.7mS	
Open Thermocouple Detect Current	50 nA	RTD Excitation Current	250 μA	

# $\boldsymbol{i}^{\scriptscriptstyle 3}$ C Mini Intelligent Control Station



J1 (Orange)	Name
11	IN1
12	IN2
13	IN3
14	IN4
15	IN5
16	IN6
17	IN7
18	IN8
H1	HSC1 / IN9
H2	HSC2 / IN10
Н3	HSC3 / IN11
H4	HSC4 / IN12
NC	No Connect
NC	No Connect
OV	Common





J2 (Black)	Name
0V	Common
V+	Output Power
NC	No Connect
Q12	OUT12
Q11	0UT11
Q10	OUT10
Q9	OUT9
Q8	OUT8
Q7	OUT7
Q6	OUT6
Q5	OUT5
Q4	OUT4
Q3	OUT3
Q2	OUT2 / PWM2
Q1	OUT1 / PWM1


Digital Outputs		
	0V	
-0+	V+	
10 - 30VDC	NC	
- LOAD +	Q12	
- LOAD +	Q11	
- LOAD +	Q10	
- LOAD +	Q9	
- LOAD +	Q8	
- LOAD +	Q7	
- LOAD +	Q6	
- LOAD +	Q5	
- LOAD +	Q4	
- LOAD +	Q3	
- LOAD +	Q2	
- LOAD +	Q1	4

J2 (Black) Positive Logic

J3 (Orange)	Name
T1+	TC (1+) or RTD (1+) or 100mV (1+)
T1-	TC (1-) or RTD (1-) or 100mV (1-)
T2+	TC (2+) or RTD (2+) or 100mV (2+)
Т2-	TC (2-) or RTD (2-) or 100mV (2-)
AQ1	10V or 20mA Out (1)
AQ2	10V or 20mA Out (2)
OV	Common
MA1	0-20mA In (1)
V1	0-10V In (1)
0V	Common
MA2	0-20mA In (2)
V2	0-10V In (2)
0V	Common










Location of I/O jumpers (JP1-JP4) and wiring connectors (J1-J4) with back cover removed.

### **Jumper Setting Details**







# $oldsymbol{i}^3$ C Mini Intelligent Control Station



# Safety

**WARNING:** Battery may explode if mistreated. Do not recharge, disassemble or dispose of in fire.

WARNING: EXPLOSION HAZARD - BATTERIES MUST ONLY BE CHANGED IN AN AREA KNOWN TO BE NON-HAZARDOUS

This equipment is suitable for use in Class 1, Division 2, Groups A, B, C and D or Non-hazardous locations only.

### FOR U.S. & CANADA ONLY

Power input and output (I/O) wiring must be in accordance with Class 1, Division 2 wiring methods of the National Electric Code, NFPA70 for installations in the U.S. or as specified in Section 18-1J2 of the Canadian Electric Code for installations within Canada and in accordance with the authority having jurisdiction.

**WARNING: EXPLOSION HAZARD** - Do not disconnect equipment unless power has been switched off or the area is known to be non-hazardous.

**WARNING: EXPLOSION HAZARD** - Substitution of components may impair suitability for Class 1, Division 2.

Digital outputs shall be supplied from the same source as the i3 Controller.

WARNING: Only qualified electrical personnel familiar with the construction and operation of this equipment and the hazards involved should install, adjust, operate, or service this equipment. Read and understand this manual and other applicable manuals in their entirety before proceeding. Failure to observe this precaution could result in severe bodily injury or loss of life.

WARNING: To avoid the risk of electric shock or burns, always connects the earth ground before making any other connections.

**WARNING:** To reduce the risk of fire, electrical shock, or physical injury it is strongly recommended to fuse all Power Sources connected to the i3 controller. Be sure to locate fuses as close to the source as possible.

**WARNING:** Replace fuse with the same type and rating to provide protection against risk of fire and shock hazards.

WARNING: In the event of repeated failure, do not replace the fuse again as a repeated failure indicates a defective condition that will not clear by replacing the fuse.

Jumpers on connector JP1 and others shall not be removed or replaced while the circuit is live unless the area is known to be free of ignitable concentrations of flammable gases or vapours.

# **Common Cause of Analogue Input Tranzorb Failure**

If a 4-20mA circuit is initially wired with loop power, but without a load, the analogue input could see 24VDC. This is higher than the rating of the tranzorb. This can be solved by NOT connecting loop power prior to load connection, or by installing a low-cost PTC in series between the load and analogue input.

