



Product Service

# CERTIFICATE

No. B 17 08 99618 001

**Holder of Certificate:** Rongwei Electric Co., Ltd

Lilong Village, Liushi Town  
 325604 Yueqing City, Zhejiang Province  
 PEOPLE'S REPUBLIC OF CHINA

**Production Facility(ies):** 99618

**Certification Mark:**



**Product:** Cable gland

**Model(s):**

**Non-metallic cable gland:**  
 M12X1.5, M16X1.5, M20X1.5, M25X1.5, M32X1.5,  
 M40X1.5, M50X1.5, M63X1.5, PG7, PG9, PG11,  
 PG13.5, PG16, PG21, PG29, PG36, PG42, PG48,  
 MG12A, MG16A, MG20A, MG25A, MG32A, MG40A,  
 MG50A, MG63A, PG7A, PG9A, PG11A, PG13.5A,  
 PG16A, PG21A, PG29A, PG36A, PG42A,  
**Metallic cable gland:**  
 M12X1.5-MA, M16X1.5-MA, M20X1.5-MA, M25X1.5-MA,  
 M32X1.5-MA, M40X1.5-MA, M50X1.5-MA, M63X1.5-MA,  
 PG7-MA, PG9-MA, PG11-MA, PG13.5-MA, PG16-MA,  
 PG21-MA, PG29-MA, PG36-MA, PG42-MA, PG48-MA

<b>Parameters:</b>	Material of the cable glands:	Non-metallic / Metallic
	Type of anchorage:	Type A
	Impact category:	Category 2
	Degree of protection:	IP68 (IPX8: 2m; 30 min)
	Temperature range:	-20°C to 100 °C
	Sealing system:	With a single orifice seal

**Tested according to:** EN 62444:2013

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

**Test report no.:** 64100170247101

**Valid until:** 2022-08-16

**Date,** 2017-08-17

*Boris Ouyang*  
 ( Boris Ouyang )

Page 1 of 1





Product Service

# Attestation of Conformity

No. N8A 17 08 99618 002

**Holder of Certificate:** Rongwei Electric Co., LtdLilong Village, Liushi Town  
325604 Yueqing City, Zhejiang Province  
PEOPLE'S REPUBLIC OF CHINA**Product:** Cable gland**Model(s):****Non-metallic cable gland:**M12X1.5, M16X1.5, M20X1.5, M25X1.5, M32X1.5,  
M40X1.5, M50X1.5, M63X1.5, PG7, PG9, PG11,  
PG13.5, PG16, PG21, PG29, PG36, PG42, PG48,  
MG12A, MG16A, MG20A, MG25A, MG32A, MG40A,  
MG50A, MG63A, PG7A, PG9A, PG11A, PG13.5A,  
PG16A, PG21A, PG29A, PG36A, PG42A,**Metallic cable gland:**M12X1.5-MA, M16X1.5-MA, M20X1.5-MA, M25X1.5-MA,  
M32X1.5-MA, M40X1.5-MA, M50X1.5-MA, M63X1.5-MA,  
PG7-MA, PG9-MA, PG11-MA, PG13.5-MA, PG16-MA,  
PG21-MA, PG29-MA, PG36-MA, PG42-MA, PG48-MA**Parameters:**

Material of the cable glands:

Non-metallic / Metallic

Type of anchorage:

Type A

Impact category:

Category 2

Degree of protection:

IP68 (IPX8: 2m; 30 min)

Temperature range:

-20°C to 100 °C

Sealing system:


With a single  
orifice seal**Tested  
according to:**

EN 62444:2013

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

**Test report no.:**

64100170247101

**Date,** 2017-08-17  
( Boris Ouyang )

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.

Page 1 of 1